Declaration of Performance

Nr.: DoP-960.01

1. Unique identification code of the product-type:

Electromechanical striking plate (Electric strike) according to DIN EN 14846:2008 Electric strike Modell 960 in all variants

2. Intended use/es:

Electric strike for smoke and fire doors according to DIN EN 14846:2008

3. Manufacturer:

ASSA ABLOY Sicherheitstechnik GmbH Bildstockstraße 20 72458 Albstadt DEUTSCHLAND

4. Authorised representative:

N.N

5. System/s of AVCP:

System 1 according to DIN EN 14846:2008

6. a Harmonised standard:

Notified body		Certificat of Constancy of performance
MPA NRW, Marsbruchstraße 186; D-44287 Dortmund, Kennung:0432	DIN EN 14846:2008	0432-CPR-00007-04 (22.12.2015)

The product is covered by other EC-directives:

Document	Identification	Date
EC-Declaration of Conformity (ASSA ABLOY Sicherheitstechnik GmbH, Bildstock 20, D72458 Albstadt)	DoC-960.01	11.01.2016

6.b European Assessment Document:

N.N

7. Declared performance/s:

Declared performance according to EN 14846:2008

Requirement / characteristic	Section	Performance	Harmonisend standard
Self-closing ability	5.4 and annex A	Closing force from a standing start passed Return force of latch bolt passed	EN 14846:2008
Durability of self-closing action	5.3.2	Durability passed Number of test cycles passed	EN 14846:2008
Resistance to fire E (integrity) I (insulation) (for fire doors)	5.5	Fire test passed	EN 14846:2008

Classification code according to DIN EN 14846:2008

Position	1	2	3	4	5	6	7	8	9	
Section	4.3	4.4	4.5	4.6	4.7	4.8	4.9	4.10	4.11	
Class	3	Υ	9	D	-	0	0	0	1	
Class	3	Y	9	D	-	0	0	1	1	

Pos.	Ess. characteristics	Class-Performents
1	Application class	 1 - For use by persons with large incentive for care 2 - For use by persons with some incentive for care 3 - For use by persons with less incentive for care
2	Lasting functionability and load of the keeper	A - 50.000 testing cycles, no load of the keeper B - 100.000 testing cycles, no load of the keeper C - 200.000 testing cycles, no load of the keeper F - 50.000 testing cycles, load of the keeper 10 N G - 100.000 testing cycles, load of the keeper 10 N H - 200.000 testing cycles, load of the keeper 10 N L - 100.000 testing cycles, load of the keeper 25 N M - 200.000 testing cycles, load of the keeper 25 N R - 100.000 testing cycles, load of the keeper 50 N S - 200.000 testing cycles, load of the keeper 50 N W - 100.000 testing cycles, load of the keeper 120 N X - 200.000 testing cycles, load of the keeper 120 N Y - 200.000 testing cycles, load of the keeper 250 N
3	Door weight and closing force	1 - ≤ 100 kg door weight, max 50 N closing force 2 - ≤ 200 kg door weight, max 50 N closing force 3 - > 200 kg defined by the manufacturer, max 50 N closing force 4 - ≤ 100 kg door weight, max 25 N closing force 5 - ≤ 200 kg door weight, max 25 N closing force 6 - > 200 kg defined by the manufacturer, max 50 N closing force 7 - ≤ 100 kg door weight, max 15 N closing force 8 - ≤ 200 kg door weight, max 15 N closing force 9 - > 200 kg defined by the manufacturer, max 50 N closing force
4	Suitability for use in smoke and fire doors	0 - Not intended for use on smoke/fire door assemblies A - Suitable for use on smoke door assemblies B - With a classification time of 15 min C - With a classification time of 30 min D - With a classification time of 60 min E - With a classification time of 90 min F - With a classification time of 120 min or greater
5	Security (personal protection)	0 - No safety requirements

6	Environmental conditions	0 — Corrosion none, Temperature none, Humidity none A — Corrosion none, Temperature none, Humidity Grade 1 B — Corrosion none, Temperature none, Humidity Grade 2 C — Corrosion low resistance, Temperature +5°C to +55°C, Humidity Grade 1 D — Corrosion medium resistance, Temperature +5°C to +55°C, Humidity Grade 1 E — Corrosion high resistance, Temperature +5°C to +55°C, Humidity Grade 1 F — Corrosion very high resistance, Temperature +10°C to +55°C, Humidity Grade 1 G — Corrosion medium resistance, Temperature -10°C to +55°C, Humidity Grade 1 H — Corrosion high resistance, Temperature -10°C to +55°C, Humidity Grade 1 J — Corrosion wery high resistance, Temperature -25°C to +70°C, Humidity Grade 2 L — Corrosion high resistance, Temperature -25°C to +70°C, Humidity Grade 2 M — Corrosion very high resistance, Temperature -25°C to +70°C, Humidity Grade 2 N — Corrosion none, Temperature -25°C to +70°C, Humidity Grade 1 G — Corrosion none, Temperature -25°C to +70°C, Humidity Grade 2
7	Security (burglary resistance)	 Applies for locks without any protective effect Minimum protective effect without drilling resistance Low protective effect without drilling resistance Medium protective effect without drilling resistance High protective effect without drilling resistance High protective effect with drilling resistance Very high protective effect with drilling resistance Very high protective effect with drilling resistance
8	Protective effect of the electrical functions	0 - No requirements 1 - Status indicator according to 5.9 EN 14846:2008
9	Protective effect of the electrical manipulation	0 - No requirements 1 - See DIN EN 14846:2008-11 table 7 2 - See DIN EN 14846:2008-11 table 7 3 - See DIN EN 14846:2008-11 table 7

8. Appropriate Technical Documentation and/or Specific Technical Documentation:

N.N

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above

Signed for and on behalf of the manufacturer by:

Stephan Fischbach, Managing Director

At Albstadt on 11.01.2016

ASSA ABLOY Sicherheitstechnik GmbH Bildstockstraße 20 72458 Albstadt DEUTSCHLAND Tel. + 497431 123-0 Fax + 497431 123-240 ASSA ABLOY is the global leader in door opening solutions, dedicated to satisfying end-user needs for security, safety and convenience.

www.assaablov.com