



Distributed by: UNION Ltd
School Street
Willenhall
WV13 3PW

www.uniononline.co.uk/DoP

Conformance Information

Identification Number of Certified body: 1121

EC Certificate of Conformity No: 1121-CPR-AD5338

UNION CE24V and N8824 BC Rack and Pinion Door Closer

This product has been third party tested to: BS EN 1154 : 1997

Year in which marking was applied:

17

This range achieves the following classifications:

CE24V door closer

3	8	4/2	1	1	3
---	---	-----	---	---	---

N8824 BC door closer

3	8	4/2	1	1	3
---	---	-----	---	---	---

Note: Products have been included in a fire test to BS EN 1634-1. These door closers have been assessed against prime evidence for timber doors up to FD120.

The following Declaration of Performance numbers are available at www.uniononline.co.uk/DoP

Product Code	DoP Number
J-CE24V	0124DCD
J-N8824BC	0124DCD

24V-CE-CONFORMANCE INFORMATION-30062017
Issue: 1.0 JUNE 2017

Trusted by **Professionals**



FIRE DOORS!

When this product is fitted to fire doors, it is not required to be fitted with intumescent material.

MAINTENANCE INFORMATION

Inspect regularly to ensure the closer body and armset is fixed securely to the door and frame.

Check the armset screws remain tight.

Once a year, check the closing time and adjust closing speed and latch speed valves if required to ensure the closer seats the door fully into the frame and allows any latch bolts on the door to locate into their keeps.

Trusted by **Professionals**

